

No.170

Dated: 01/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Godavari English Medium School, Jalgaon** (name of the building or premises) at **Plot No. 54, Near Bharat Petroleum Add| MIDC, Bhusawal Road, Jalgaon** (address) comprised of **Block (1) G+2 & Block (2) G+2 basement (s) and Laboratories, Library, Office, Computer Lab & All Rooms** (upper floors) owned/occupied by **Godavari Foundation's Godavari English Medium School, Jalgaon** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on **01/05/2025** (date of inspection) in the presence of **Mrs. Nilima Rajendra Chaudhari (Principal)** (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy up to classes **Primary, Secondary & Higher Secondary Level (X/ XII)** With effect from **01/05/2025** for a period of **1** year in accordance with rule and subject to compliance of specific conditions.

- 1.
- 2.
- 3.

Issued on 01/05/2025 (date of issue) at **Jalgaon** (place) by

\*Strike out whichever is not applicable.



Signature with Seal :-

Name

**Sashikant L. Bari**

Designation

**: Fire Officer,**

**Jalgaon City Municipal Corporation, Jalgaon**

Name & Address of Department/Office:

To,

**Principal,**

**Godavari English Medium School, Jalgaon**

**Plot No. 54, Near Bharat Petroleum Add| MIDC, Bhusawal Road, Jalgaon.**

(Name & Address of the Institution)

**ENDORSEMENT**

The No Objection Certificate issues by Fire Service stand cancelled an annulled due to **If not refill fire extinguisher timely** (reasons to be recorded).

(Name and designation of the authorized signatory)



**PRINCIPAL**  
**Godavari English Medium School**  
**Jalgaon**

**India Automation & Fire Solutions**

(ISO 9001:2015 Certified Company)

Pushkardeep, 305, 3rd Floor, Sr. No. 116/5/1, Plot No. B,

Mumbai-Bengaluru Bypass, Next to McDonald's, Warje, Pune - 411 058

Email: jwbadhe@gmail.com / jwbadhe@iafspune.com / info@iafspune.com

Web: www.iafspune.com 24 hours helpline: +91- 98225 24984 / 77740 52101

**FORM A**

{{(See Section 3(3) and rules 4(1))}}

**Certificate by the Licensed Agency regarding the compliance of the Fire Prevention and Life Safety Measures.**

**CERTIFICATE**

Certified that I/We have executed the work towards compliance in relation to Fire Prevention and Life Safety Measures to be provided and performed other related activities required to be carried out, in the following building or premises as required under the Provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007)

Description and Location of Building or Premises

**M/s. Godavari Foundation Godavari English Medium School**

**Jalgaon, Plot No.P-54, Near Bharat Petroleum,**

**ADD| MIDC,Bhusawal Road,Jalgaon.**

**State Name : Maharashtra, Code : 27**

The details of the work and related activities which I or We have executed or performed are mentioned in the list appended herewith.



**JITENDRA  
WAMAN  
BADHE**

Digitally signed by  
JITENDRA WAMAN  
BADHE  
Date: 2025.05.30  
10:07:17 +05'30'

**Place: Pune**

**Date: 30/05/2025**

Signature and address of the Licensed Agency

License No. **MFS-LA/RF-258**  
**MFS-LA/RD -238**



  
**PRINCIPAL**  
**Godavari English Medium School**  
**Jalgaon**



**Details of Fire Fighting Equipment Install at At,  
M/s. Godavari Foundation Godavari English Medium School**

Jalgaon Plot No.P-54,  
Near Bharat Petroleum  
ADD| MIDC,Bhusawal Road,Jalgaon  
State Name : Maharashtra, Code : 27

Sr. No.	PARTICULARS	Unit	QTY	Remark
<b>FIRE HYDRENT SYSTEM</b>				
1	Fire Escopce Hydrant	Nos	3	Installed in Building
2	Hydrant Valve:	Nos	9	Installed in Building
3	Short Branch Pipe	Nos	9	Installed in Building
4	R.R.L. Hose Pipe	Nos	9	Installed in Building
5	Single Hose Box	Nos	9	Installed in Building
6	Hose Reel Drum	Nos	9	Installed in Building
7	CI Ball Valve Size:-20 mm Dia.	Nos	9	Installed in Building
8	Cautionary Sign Board	Nos	10	Installed in Building
<b>FIRE EXTINGUISHER</b>				
1	ABC Type Fire Extinguisher 6 kg	Nos	12	Installed in Building
<b>BOOSTER PUMP</b>				
1	Overhead Booster pump 900 Lpm (10 Hp)	Nos	1	Installed in Building

For,

**India Automation & Fire Solutions**



**JITENDRA  
WAMAN  
BADHE**

Digitally signed by  
JITENDRA WAMAN  
BADHE  
Date: 2025.05.30  
10:12:59 +05'30'

Authorized Signatory  
Stamp with Seal



**PRINCIPAL**  
**Godavari English Medium School**  
**Jalgaon**





**Govt. of Maharashtra**  
**Directorate of Maharashtra Fire Service**  
Vidyanagri, Hans Bhugra Marg, Santacruz (East),  
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666  
www.mahafireservice.gov.in

**FORM N**  
**[ ( See section 9 (3) and rule 14 )**  
**License to act as a License Agency for the purpose of**  
**Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-258 / RD-238

Date: 04.05.2024

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. India Automation & Fire Solutions** having their registration office at **Pushkardeep, 305, Sr.No. 116/5/1, Plot B, Mumbai Bangaluru Bypass, Warje, Pune 411058** and their contact details are Office Number: 9822524984 and Email ID: jwbadhe@gmail.com with PAN registration No. ALOPB0205D and GST No. 27ALOPB0205D1ZS to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- |  |                |
|--|----------------|
| <b>1. Fire Fighting and Sprinkler System:</b>    | <b>Class A</b> |
| <b>2. Detection and Fire Suppression System:</b> | <b>Class A</b> |

**M/s. India Automation & Fire Solutions** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **04.05.2024 to 03.05.2026**

**Hatya**  
**| Kiran**

Digitally signed  
by Hatya Kiran  
Date: 2024.05.10  
16:57:08 +05'30'

Asst Director

**JITENDRA**  
**WAMAN**  
**BADHE**

Digitally signed by  
JITENDRA WAMAN  
BADHE  
Date: 2024.05.10  
16:45:28 +05'30'

FOR FORM A  
Godavari Foundation Godavari English  
Medium School, Jalgaon Plot No.P-54, Near  
Bharat Petroleum, ADDI  
MIDC, Bhusawal Road, Jalgaon

**Santosh**  
**Warick**

Digitally signed by  
Santosh Warick  
Date: 2024.05.10  
17:06:00 +05'30'

( S S Warick )  
Director

Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

\* in absence of digital sign of license holder responsible to issue Form A or Form B) the license will be treated as invalid.



**PRINCIPAL**

**Godavari English Medium School**  
**Jalgaon**



This license has been issued under the provisions in section 9 (5) and section 18 (2) and is valid in all Local Authorities as defined in section 2 (7) & Planning Authorities as defined in section 2(12) of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be :-

- a) Non-transferable
- b) Valid for two year from the date of issue, unless suspended or cancelled earlier.
- c) Renewable, if so desired, before expiry of the licence.

2. Changes, if any. In respect of the –

- a) Partners, Directors or Members
- b) Address of the office of the License Agency

Shall be forthwith reported to the Directorate of Maharashtra Fire Service.

3. The Licensed Agency shall always keep the work executed or being executed, open for inspection by the Director, or any Fire Officer authorized by the Director.

4. The Licensed Agency shall issue a certificate in Form "A" to the client in respect of the works executed by them and shall issue a six monthly certificate in Form –"B", in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient conditions at all times.

5. Refer Circular issued by this Office vide No. MFS/51/2022/236, dated 15.02.2022

6. **M/s. India Automation & Fire Solutions (Proprietor) has paid amount of Rs. 50,000/- (Rs. Fifty Thousand Only) vide UTR No. SBIN224099871417, dated 08.04.2024 towards registration fees.**



  
**PRINCIPAL**  
**Godavari English Medium School**  
**Jalgaon**

Govt. of Maharashtra  
Directorate of Maharashtra Fire Service  
Vidyanagri, Hans Bhugra Marg, Santacruz (East),  
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666  
[www.mahafireservice.gov.in](http://www.mahafireservice.gov.in)